



Single Family

No License required currently

Testing Standard
ICC/RESNET 380

Provide test results to AHJ & Owner

4@ACH50
Negative or Positive

R402.4.1.2

Multifamily

Certification Required

ASTM E779
ASTM E1827
ASTM E3158

Provide test results to AHJ & Owner

0.25cfm/sf of DUEA @50PA (WSEC-R)
Positive and/or Negative
(see standard chosen)

You must pass the test!

No guarded testing

R402.4.1.3.2 Group R-2 multifamily building leakage rate. For Group R-2 multifamily buildings, the maximum leakage rate for any dwelling unit shall not exceed 0.25 cfm per square foot of the dwelling unit enclosure area. Testing shall be conducted with a blower door at a test pressure of 0.2 inches w.g. (50 Pa).

Doors and windows of adjacent dwelling units (including top and bottom units) shall be open to the outside during the test.